APPENDIX 1: DESIGN VERIFICATION

| DESIGN VERIFICATION of IEC 61439-1, Clause 10, Edition 3.0 (2020.05) | | | Limitation of IEC 61439-1&2 (L) or Decleration of Orginal Manufacturer (D) | VERIFICATION of PDS SWITCHBOARDS IN 4000A SYSTEM | Tested by |
|--|--|--|---|---|-------------------|
| 10.2 | Strength of materials and parts | Explanations | | | |
| 10.2.2 | Resistance to Corrosion | In all cases, hinges, locks and fastenings shall also be tested unless they have previously been subjected to an equivalent test and their resistance to corrosion has not been compromised by their application. | (L)Limited | Severity Test A : Indoor | DEKRA Sep.2020 |
| 10.2.3 | Properties of insulating materials | Verification of thermal stability of enclosures / Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | (L)Limited | Dry Heat Tested according to IEC 60068-2-2 Test Bb Glow Wire Tested according to IEC 60695-2-10/11 | DEKRA Sep.2020 |
| 10.2.4 | Resistance to ultraviolet (UV) radiation | This test applies only to enclosures and external parts of assemblies intended to be installed outdoors and which are constructed of insulating materials or enclosures that are entirely coated by synthetic material. | NONE | Applying at only Insulated material Enclsoures | NONE |
| 10.2.5 | Lifting | The maximum number of sections allowed by the original manufacturer to be lifted together shall be equipped with components and/or weights to achieve a weight of 1,25 times its maximum shipping weight. With doors closed, it shall be lifted with the specified lifting means and, in the manner, defined by the original manufacturer. | (L)Limited | The Verification of the lifting done in confirmity with IEC 61439-2 cluase 10.2.5 Assembly weigth was : 3.288kg Tested weigth was : 4.148kg | DEKRA Sep.2020 |
| 10.2.6 | Verification of protection against mechanical impact (IK code) | Protection levels verified against impacts from outside to the enclosure | (D) Declerated | IK 10 is tested and declarated by PDS | PDS July 2020 |
| 10.2.7 | Marking | After the test, the marking shall be legible to normal or corrected vision without additional magnification. | (L)Limited | Markings tested and declarated by PDS | PDS July 2020 |
| 10.2.8 | Mechanical operation | Movable parts like interlocks, locks , doors are tested work 200 times. | (L)Limited | The Verification of the lifting done in confirmity with IEC 61439-2 clause 10.2.8 Regular doors , doors with rotary handle and withdrawable units opended-closed in 200 cycles | DEKRA Sep.2020 |
| 10.3 | Degree of protection of assemblies (IP Code) | Protection against solid and liquid objects of switchboard.See at Appendix 3. | (D) Declerated | The Verification done with IEC 60529 confirmity of IEC 61439-2 clause 10.3 Decleration of PDS was IP53 FOR PCC modules IP40 for withdrawable modules. The result was: pass. | DEKRA Sep.2020 |
| 10.4 | Clearances and creepage distances | Protection distances of live conductors to unlive conductors an each other are verifed. See at Appendix 4 | (L)Limited | The Verification done in confirmity with IEC 61439-2 clause 10.4 Main busbars, Distribution busbars, MCCBs, DOL&DSD withdrawable units clerances and creepage distances are measured. The distances are determined confirmity with Uimp: up to 12kV and Ui: up to 1000V | DEKRA Sep.2020 |



APPENDIX 1: DESIGN VERIFICATION

| DESIGN VERIFICATION of IEC 61439-1, Clause 10, Edition 3.0 (2020.05) | | | Limitation of IEC 61439-1&2 (L) or Decleration of Orginal Manufacturer (D) | VERIFICATION of PDS SWITCHBOARDS IN 4000A SYSTEM | Tested by |
|--|--|---|--|--|-------------------|
| 10.5 | "Protection against electric shock and integrity of protective circuits" | | | | |
| 10.5.2 | Effective earth continuity between the exposed- conductive-parts of the class I assembly and the protective circuit" | It verified that the different exposed-conductive-parts of the assembly are effectively connected to the terminal for the incoming external protective conductor. Verification shall be made using a resistance-measuring instrument that is capable of driving a current of at least 10 A (AC or DC). The current is passed between each exposedconductive part and the terminal for the external protective conductor. The resistance shall not exceed 0,1 Ω . | (L)Limited | The Verification done with confirmity of IEC 61439-2 clause 10.5.2 decleration of PDS. | PDS July 2020 |
| 10.5.3 | Short-circuit withstand strength of the protective circuit | The rated short-circuit withstand strength shall be verified for protection circuits. | (D) Declerated | The Verification done in confirmity with IEC 61439-2 clause 10.5.3.5 Main PE Busbar = L3-PE: lcw:60kA-1s, 132kA peak Vetical PE Busbar 1 = L3-PE: lcw:48kA-1s, 100,8kA peak Vetical PE Busbar 2 = L3-PE: lcw:36kA-1s, 75,6kA peak | DEKRA Sep.2020 |
| 10.6 | Incorporation of switching devices and components | These are rules concerning the installation of devices included in the assembly, whether they are fixed or removable parts and compliance with the customer's wiring requirements. This also includes accessibility to adjustment and reset devices; and all types of indication (LEDs,dials, etc.). | (L)Limited | The Verification done in confirmity with IEC 61439-2 clause 10.6 | DEKRA Sep.2020 |
| 10.7 | Internal electrical circuits and connections | This test consists of checking conformity of the power and control circuits with the design requirements. It includes correct sizing of the busbar and cables, earthing the control circuits, etc. It also includes identification of the various circuits using different colours. | (L)Limited | The Verification done in confirmity with IEC 61439-2 clause 10.7 | DEKRA Sep.2020 |
| 10.8 | Terminals for external conductors | This rule requires the terminal capacity and whether the terminals are suitable for aluminium or copper conductors to be specified to the end user. It also includes checking all the types of terminal that can be used for the cable entries and outlets (neutral, PEN, symbolic PE, etc.). | (L)Limited | The Verification done in confirmity with IEC 61439-2 clause 10.8 | DEKRA Sep.2020 |
| 10.9 | Dielectric properties | | | | |
| 10.9.2 | Power-frequency withstand voltage | The rated insulation voltage of a circuit of an assembly is the voltage value to which dielectric test voltages and creepage distances are referred. (Ui) See at Appendix 2 | (L)Limited | The assembly was subjected for 60 seconds to a high voltage test no breakdown or flash-over ocuured during the tests. Ui:1000V, Uimp: 12kV: - Main and Distribution Busbars, ACB's 2500A-4000A,MCCB's 400A-1600A Ui:800V-690V, Uimp: 8kV-4kV: - Withdrawable Units DSD 30-110kW, DOL 15-15kW, PCC 160A External operating handles of insulating materials tested. | DEKRA Sep.2020 |
| 10.9.3 | Impulse withstand voltage | The rated impulse voltage of an assembly is the voltage value to which clearance distances and solid insulation withstand to transient overvoltage are referred. (Uimp) See at Appendix 2 | | | |
| 10.9.5 | External operating handles of insulating materials tested. | "The rated insulation voltage of a circuit of an assembly is the voltage value to which dielectric test voltages and creepage distances are referred. (Ui)" | | | |



APPENDIX 1: DESIGN VERIFICATION

| DESIGN VERIFICATION of IEC 61439-1, Clause 10, Edition 3.0 (2020.05) | | | Limitation of IEC 61439-1&2 (L) or Decleration of Orginal Manufacturer (D) | VERIFICATION of PDS SWITCHBOARDS IN 4000A SYSTEM | Tested by |
|--|-------------------------------------|--|---|--|-------------------|
| 10.10 | Temperature rise limits | Permissible limited temperature rising limits on different parts of an assembly than the tested ambient temprature on maxiumum Rated Currency (In) * Busbarbars and Conductors: 105K (limited insulated holder capabilities too) * Terminals for external insulated conductors: 70K *Manual operating:of metal: 15K, insulating material: 25K * Accessible external enclosures and covers: metal surfaces: 30K, insulating surfaces: 40K Note 1: K = Δt Measured Temperature °C - Ambient temperature °C Note 2: Ambient temrature is daily average temp. | (D) Declerated | Test was done at IP53 without air forced for PCC modules, IP 40 without air forced for withdrawable modules *ACB 4000A Schneider NW40 H2 at 35°C ambient conditions supply with 2970A limited on only upper fixed terminal of ACB *ACB 4000A Schneider NW40 H2 at 50°C ambient conditions supply with 2500A limited on only upper fixed terminal of ACB * Other measured points were kept belower than the rising limits. For all rising results please see at Dekra Test certificate * For choosing the correct system related with temprature rising please see at guide for Users | DEKRA Sep.2020 |
| 10.11 | Short-circuit withstand strength | Assemblies shall be capable of withstanding the thermal and dynamic stresses resulting from short-circuit currents not exceeding the rated values. Rated short-time withstand current (Icw) together with the associated duration and rated peak withstand current (Ipk) | (D) Declerated | Main Busbar: 80/10 x 4 L1,L2,L3 = Icw: 80kA 1s, Ipk: 176kA Main Busbar: 80/10 x 4 L3-N = Icw: 60kA 1s, Ipk: 132kA Distribution Busbar: 80/10 x 4 L1,L2,L3 = Icw: 80kA 1s, Ipk: 176kA Distribution Busbar: 80/10 x 2 L3-N = Icw: 48kA 1s, Ipk: 100,8kA Withdrawable Busbar: 60/10 x 1 L1,L2,L3 = Icw: 60kA 1s, Ipk: 132kA Neuteral in Cable Comp.: 30/10 x 2 L3-N = Icw: 36kA 1s, Ipk: 75,6kA * For all busbar results please see at Dekra Test certificate | DEKRA Sep.2020 |
| 10.12 | Electromagnetic compatibility (EMC) | This test consists of checking the electromagnetic interference caused by the assembly when operating in its environment, the aim being for it to causeno interference. | (L)Limited | The Verification done in confirmity with IEC 61439-2 clause 10.12 | DEKRA Sep.2020 |

